

# CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

BOD-19-06-04-01

- Products:** SPC Floorings "Vinyl Tile Floorings", Structure: Antique wood texture (BP)  
Dimensions: length (600-1840) mm x width (150-600) mm x thickness (3.2-7.0) mm
- Client:** Changzhou Huaren Decorative Materials Co., Ltd.  
No. 110, Changhong Road, Wujin District, Changzhou City, Jiangsu Province, China
- Order:** Testing and classification of selected properties according to EN 14041:2008 (CE-labelling)
- Test report:** 278003/138
- Test results:** *The above mentioned SPC Floorings floorings can be classified regarding to the tested properties according to EN 14041:2008 (CE-labelling) as follows:*

Properties	Results	Declaration according to EN 14041:2008
Reaction to fire performance according to EN ISO 9239-1 and EN ISO 11925-2, Classification according to EN 13501-1:2010 - Critical heat flow - Smoke production	11.4 kW / m <sup>2</sup> 569 % x min	Reaction to fire class B <sub>f</sub> -s1
Sliding properties according to EN 13893:2003	μ = 0.47	class DS

Dresden, 04/06/2019

Head of laboratory



Engineer in charge